



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

TEST REPORT

Customer: C0484993

Transceram Gmbh
Heinrich-Lanz-Str.10
69514
Laudenbach
Germany

| | |
|-----------------|---|
| Result | Limited testing was undertaken on this product in accordance with the WRAS Material Guidance document, Section 7.6 (ceramic). This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water. |
| Customer Name | Transceram Gmbh |
| Product | Ceramic Valve Material (SiSiC 8-12% Free Silicon) |
| Test Undertaken | BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water |
| Job Number | J-00340747 |
| PAMS Number | 190699 |

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 16-OCT-2019

Report Authorisation *M Rees*
Matthew Rees - Materials Laboratory Supervisor



0626