



Customer: C0484993

Transceram GmbH
Heinrich-Lanz-Str.10
69514
Laudenbach
Germany

Result	Limited testing was undertaken on this product in accordance with the WRAS Material Guidance document, Section 7.6 (ceramic). This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.
---------------	---

Customer Name	Transceram GmbH
Product	ZrO ₂ (TC-ZrO ₂) Zirconia Ceramic
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00341369
PAMS Number	190703

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 11-NOV-2019

Report Authorisation

Michael Bustin - Materials Testing Manager



0626